

Approval Number: 1803518
Test Report: MAT/LAB 237B



Water Regulations Advisory Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

1st June 2018

Keramo SPA
Via Rovascio 56,
22038 Tavernerio (Como),
Italy

WATER REGULATIONS ADVISORY SCHEME LTD. (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

CERAMIC

5023

'Kersic 1000'. Grey coloured, compression moulded silicon carbide. For use with water up to 85°C.

APPROVAL NUMBER: 1803518
APPROVAL HOLDER: KERAMO SPA

The Scheme reserves the right to review approval.
Approval 1803518 is valid between March 2018 and March 2023

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wras.co.uk/directory

Yours faithfully

A handwritten signature in blue ink, appearing to read 'Jason Furnival', written in a cursive style.

Jason Furnival
Approvals & Enquiries Manager
Water Regulations Advisory Scheme